



SUNBELT transformer
 303 B Greer Dr.
 Simpsonville, SC 29681
 Phone: 864-228-4831

LV SWITCHGEAR
 FAX TO: 864-228-4834

Customer Name:	Replacement?	yes no	
Customer Contact Name:	New	Reconditioned	
Address:	Delivery Date:	days	weeks
City: State: Zip: Country:	Telephone #: Ext.:		
Fax #:	E-mail:		
Sales Person:			

Voltage: 208Y/120 3PH 4W 480Y/277 3PH 4W 480V 3PH 3W 600V 3PH 3W
 (circle one)

Switchboard Amperage: 400 A 600A 800A 1000A 1200A 1600A 2000A 2500A 3000A
 (circle one) 4000A

Enclosure: Indoor NEMA 1 Outdoor NEMA 3R
 (circle one)

Available Fault Current: 10K 18K 22K 30K 35K 42K 50K 65K Other _____
 (circle one)

Main Breaker: 400 A 600A 800A 1000A 1200A 1600A 2000A 2500A 3000A
 (circle one) 4000A Other _____ None needed (6 disconnect rule)

Incoming: TOP BOTTOM SIDE LEFT RIGHT
 (circle one or more)

Connections: Transition Direct mounted Stand Alone (freestanding) Other _____
 (circle one)

Ground Fault: Yes No
 (circle one)

Metering: Specify _____

Bus: (circle one) Copper Tin plated Aluminum

