

NO. 0061888800.141

THREE PHASE TRANSFORMER



SUNBELT TRANSFORMER
TEMPLE, TEXAS

4.0 %IMP BIL HV 60 LV 30kV


KVA 150
HV 4160
LB TANK 812 c&c 637 OIL TYPE II 878 LBS TOTAL 2327 LBS
LV 208Y/120 AMPS 416

CONT 65 °C RISE CLASS ONAN 60HZ
TANK DESIGNED FOR +7 PSIG
F1 ISOLATION LINK
F2 BAYONET FUSE

CONTAINS NO DETECTABLE LEVEL OF PCB (LESS THAN 2 PPM) AT THE TIME OF MANUFACTURE.

VOLTAGE PDS AMPS

4368	1/A	19.83
4264	2/B	20.31
4160	3/C	20.82
4056	4/D	21.35
3952	5/E	21.91



9150435376054

SER. NO.

SER. NO. BAR CODE

CAT. NO. BAR CODE

BLACK ANNOIDIZED ALUMINUM



SUNBELT TRANSFORMER
TEMPLE, TEXAS

NAME: LASER NAME PLATE cc 857

DESCR: RF/TP/2FUSE/2PLB/ D-Y

ID 3DBX3436 P.N. 0061888800.141

SCALE 1.000 DWG BY TB CHK BY DATE 08/12/04

REV	DATE	REVISION	BY	APP

CAT. NO. 9150435376054

3DBX3436